

No:07:School/CC/DFO/MDY/2022

OFFICE OF THE
DISTRICT FIRE OFFICER,
MANDYA DIST, MANDYA .

Date: 23.07.2022

To,

The Principal,
St. Francis School,
Bangalore Shanti Sadhana Society,
Naguvanahalli Gate , Ganjam, Post,
Srirangapatna Taluk,
Mandya District-571477.

Sir,

Sub:- Issue of Fire Safety Compliance certificate with respect to fire prevention, Fighting and evacuation measures maintained/required at M/s St. Francis School, "Bangalore Shanti Sadhana Society, Naguvanahalli Gate , Ganjam, Post, Srirangapatna Taluk, Mandya District-571477.

**Ref:-1. This office letter No.08/FSR/School/DFO/MDY/2022, dated: 21/07/2022.
2. Your request letter dated: 23/07/2022.**

With reference to the above cited subject, as per reference (1) Fire safety recommendation certificate was issued to the premises of M/s St. Francis School, "Bangalore Shanti Sadhana Society, Naguvanahalli Gate , Ganjam, Post, Srirangapatna Taluk, Mandya District-571477. with a condition to fulfill the recommendations and compliance the same within 3 months.

Now as per reference (2) the School Management of 'St. Francis School,' had requested for issue Fire Safety Compliance certificate from our department.

In this regard 'St. Francis School' building situated Naguvanahalli Gate , Ganjam, Post, Srirangapatna Taluk, Mandya District-571477. was re-inspected by me on 23/07/2022 & found that the School Management has been fulfilled the fire fighting systems and the fire fighting systems are in good working condition during my inspection.

Under the above circumstances the Karnataka Fire & Emergency Services Department is issuing the M/s St. Francis School, "Bangalore Shanti Sadhana Society, Naguvanahalli Gate , Ganjam, Post, Srirangapatna Taluk, Mandya District-571477. subject to proper maintenance of fire fighting installations in good working conditions. **This Fire Safety Compliance Certificate valid for upto 20/07/2023 and is renewable.**



Yours faithfully



District Fire Officer
Mandya District, Mandya
Karnataka Fire & Emergency Services
Mandya - 571 402